

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010826.01-R1
DATE: 08/31/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Tapco
CODE: 1247-1
REVISION DATE: 09/29/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
TAPCO, Inc. 1815 McCullough Boulevard Tupelo, MS 38801	Series "985-HV" Single Hurricane Screen Configuration: X Screen Material: Stainless Steel Mesh Frame: W-1245mm(52") H-2134mm(84") Panel: W-1245mm(49") H-2057mm(81")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: +50/-50 psf Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories.
Report No: NCTL-210-3612-1
Expiration Date: **July 31, 2019**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122