

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010027-R1
DATE: 09/25/2009
CERTIFICATION PROGRAM: Structural
COMPANY: Tapco
CODE: 1247-1
REVISION DATE: 09/29/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
TAPCO, Inc. 1815 McCullough Boulevard Tupelo, MS 38801	Series "985-HV" Triple Mulled Single Hung Hurricane Screen Configuration: OOO/XXX Screen Material: 0.033" Stainless Steel Mesh Frame: W-3886mm(153") H-2438mm(96") Fixed Sash: W-1245mm(49") H-1168mm(46") Active Sash: W-1245mm(49") H-1168mm(46")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94 ASTM E1886-05/E1996-05 ASTM E330-02	Design Pressure: +50/-50 psf Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories.
Report No: NCTL-210-3612-1/210-3612-1a
Expiration Date: May 31, 2017

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122